

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
(315) 684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Morrisville-Eaton Central School
Richard Bowie
P.O. Box 990
Morrisville, NY 13408

Report Number: 161001

Page: 1/11

Sample Number: 05191601C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:34 am
Date Received: 05/19/16 Location: 22 DF
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.00864	mg/L	05/26/16	05/26/16
Analyzed by ELAP ID#: 11393				

Sample Number: 05191602C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:35 am
Date Received: 05/19/16 Location: Stairs DF
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	05/26/16	05/26/16
Analyzed by ELAP ID#: 11393				

Sample Number: 05191603C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:36 am
Date Received: 05/19/16 Location: Girl's bath sink-middle sink
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.00319	mg/L	05/26/16	05/26/16
Analyzed by ELAP ID#: 11393				

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
(315) 684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For: Morrisville-Eaton Central School, Morrisville, NY

Report Number: 161001

Page: 3/11

used very little

Sample Number: 05191607C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:50 am
Date Received: 05/19/16 Location: Kitchen office sink
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0255	mg/L	05/26/16	05/26/16
Analyzed by ELAP ID#: 11393				

used very little

Sample Number: 05191608C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:52 am
Date Received: 05/19/16 Location: Library 35/37 sink
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0957	mg/L	05/26/16	05/26/16
Analyzed by ELAP ID#: 11393				

Sample Number: 05191609C Sample ID: M-ECS Elementary School
Collection Date: 05/19/16 Morrisville, NY
Collection Time: 6:53 am
Date Received: 05/19/16 Location: 60 DF
Time Received: 9:00 am
Matrix: Potable Water Sample Collector: K. Popino
A&P Water Testing

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0125	mg/L	06/10/16	06/13/16
Analyzed by ELAP ID#: 11393				

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
(315) 684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For: Morrisville-Eaton Central School, Morrisville, NY

Report Number: 161001

Page: 11/11

Sample Number: 05201602C Sample ID: M-ECS Elementary School
Collection Date: 05/20/16 Morrisville, NY
Collection Time: 6:30 am
Date Received: 05/20/16 Location: Kitchen left side
Time Received: 2:00 pm
Matrix: Potable Water Sample Collector: R. Bowie
M-ECS

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0126	mg/L	05/27/16	05/31/16
Analyzed by ELAP ID#: 11393				

Additional Information:

School Lead Action Level: 0.020 mg/L
mg/L=milligrams per Liter (ppm)
<=less than

Disclaimer: The laboratory interpretations of the data obtained and results reported by A & P Water Testing are believed by A & P Water Testing to be accurate and reliable for the sample(s) as received and tested. By accepting this report, the client agrees that the full extent of any and all liability for actual and consequential damages of A & P Water Testing for services performed shall be equal to the fee charged to the client for the services as liquidated damages. No part of this report shall be reproduced, except in full, without written approval of the laboratory.

Laboratory Approval:

Annette Popino 6/17/16
Annette Popino, Director Date Approved
Test results meet all requirements of NELAC, unless noted
Raised seal at right indicates original report